



OFFICE OF THE DISTRICT MAGISTRATE

Nandini Hills, Samba.
Government of J&K.

email jksam@nic.in

website: www.samba.gov.in

Ph: 01923-241143

Fax: 01923-241141

M/S Met Trade India Ltd.(Unit-III)
Sidco Industrial Complex Phase-I lane No.6,
IGC Samba.

NO:- DCS/Misc/NOC/271/ 177-83

Dated:-/17-6-2015

Sub:- Issuance of NOC to store 20.0 KL of HSD Petroleum Class-B) in under ground Tank Sidco Industrial complex Phase-I Lane 6 IGC Samba.

--

"No objection" certificate is hereby issued in favour of M/S Met Trade India Ltd.(Unit-III) Sidco Industrial Complex Phase-I lane No.6, IGC Samba to store 20.0 KL of HSD (Petroleum Class-B) in their factory premises, subject to the conditions imposed by the Director Fire and Emergency Services J&K Jammu.

STORAGE CAPACITY:

The storage capacity of HSD (Petroleum Class – B) will be 20 K.L. in one underground tank.

FIRE SAFETY RECOMMENDATIONS:

1. The tank should be in welded construction and shall be made from mild steel plate confirming to IS:2062
2. The thickness of the tank includes the corrosion allowance of 1.5mm.
3. The tank should be designed fabricated tested and inspected as per IS:10987.
4. The tank should be earthed at two points diametrically opposite ends as per Rule No. 127 of petroleum rules.
5. All valves directly mounted on tank should be in forged / cast steel construction.
6. The storage area should be surrounded by a wall or walls and floor shall be suitably finished to form sump half of the total quantity of the product for which the license is granted.
7. The floor tank farm area is sloped towards the sump pit. The outlet of this sump pit is provided with normally closed gate valve.
8. The sump valve should always be in closed position and it should be used for draining rain water.
9. No overhead or underground cables should pass through the tank farm area.

- 25. Clear space around the storage area should be kept for easy movements of fire appliances in case of any emergency.
- 26. Unwanted grass around the premises particularly near solvent storage area should not be allowed to grow.
- 27. Proper training to the staff deployed for handling first aid fire fighting equipments.
- 28. A fire point should be provided near the solvent storage area which shall have:
 - i) Nos of fire buckets filled with fine sand.
 - ii) 5 Nos offire Beaters.
 - iii) 2 Nos of Trolley & Trailor mounted dry chemical powder fire extinguishers 50 Kgs. Capacity each bearing IS: 2171 & IS 10658.

M/S Met Trade India Ltd.(Unit-III) Sidco Industrial Complex Phase-I lane No.6,IGC Samba can proceed ahead for storage of 20 KL HSD (Petroleum Class B) in their factory premises, subject to the fulfillment/implementations of above noted recommendations i.e. from Sr. No. 1 to 28 in letter and spirit and further the unit will not exceed the assessed capacity per annum.

Moreover, the unit Management is advised to strictly adopt the above precautionary measures issued by the Director Fire and Emergency Services J&K Jammu during implementation stage.

This "NOC" is totally conditional and in case of any subsequent adverse development it can be withdrawn in the interest of administration and in the larger interest of public.



By order of District Magistrate, Samba.

[Signature]
 Addl. District Magistrate,
 Samba
 Addl. District Magistrate
 Samba

Copy to the :-

- 1 Director, Fire and Emergency Services, J&K Jammu for information. This is in reference to his "NOC" No. DF&ES/GB/Insp.of unit/3608 dated 21-9-2012.
- 2. Senior Superintendent of Police, Samba for information. This is in reference to his "NOC" No. CC/12/10031/DPOS dated 21-12-2012.
- 3. General Manager, District Industries Centre, Samba for information. This is in reference to his No. DICS/423-Ind/3665 dated 7-11-2012.
- 4. Tehsildar Samba for information. This is in reference to his No.OQ/2095 dated 31-12-2014.
- 5 District Officer, State Pollution Control Board Samba for information. This is in reference to his No. SPCB/Samba/12/327 dated 3-10-2012.
- 6. Senior Manager, Estate Industrial Growth centre, Samba for information. This is in reference to his No. Sidco/IGC/157/1314 dated 5-10-2012.
- 7. District Informatics Officer, NIC, Samba for publication on website.

✓